



Supply to Savusavu Settlement, Ba (Scheme No. BA 06-10)

Notes:

1. Safety Plan to be included in tender bid.
2. Lineman and Trainee Lineman/Line worker Certificate to be included in tender bid.
3. Safety Report for 2015 to be submitted with tender.
4. List of Construction projects completed for FEA to be submitted with tender.

FIRST SCHEDULE

SPECIAL CONDITIONS OF CONTRACT

1. The works shall comprise the installation of power lines as per attached Drawing Number: A3/08/N82/325 sheet: 1.
2. Contractors are to enter labour costs of the tasks tabulated below;

Item No.	Description	Quantity	Unit Rate	Total
	Install 10.2m concrete power pole	8		
	Install 10.2m wooden power pole			
	Install 11m concrete power pole			
	Install 8m concrete pole			
	Install 14m wooden power pole			
	Install ground stay	7		
	Install fly stay			
	Install 3ph 11kV pins single crossarm (11B)			
	Install 3ph 11KV pins double crossarm (12B)			
	Install 3ph 11kV termination double crossarm (13B)			
	Install 3ph 11kV through strain double crossarm (14B)			
	Install 1ph 11kV tee off with fuse or link switch (18A)			
	Install 1ph 11KV through strain double crossarm (14A)			
	Install 1ph 11KV termination double crossarm (13A)			
	Install 1ph 11KV pins double crossarm (12A)			
	Install 1 ph 11KV pins single crossarm (11A)			
	Install 1 ph LV through strain double crossarm (4A)			
	Install 1 ph LV termination double crossarm (3A)	10		
	Install 1 ph LV pins double crossarm (2A)	2		
	Install 1 ph LV pins single crossarm (1A)	1		
	Install single pole mounted transformer c/w dressings			
	String 3 phase HV conductors (route length) - km			
	String 1 phase HV conductor (route length) - km			
	String 1 phase LV conductor (route length) - km	0.592		
	Material Transport Cost			Total
	Transportation Cost from nearest FEA Depot			
	Vegetation Management			Total
	Vegetation Management as required			

The total Contract sum for the work is \$ _____ (VIP).

3. Work schedule;
 - a) Latest date for commencement of the works: 7 days from issue of LPO.
 - b) Date of completion of Phase1 :
 - c) Date of completion of Phase 2:
 - d) Date of completion of Phase 3 :
 - e) Date of practical completion of the works : within 1 month of issue of LPO.
 - f) Date for final completion of the works:

4. For the purpose of supervising the contract on behalf of the Authority, references in the General Conditions to the Authority shall include the Unit Leader Distribution Western or his designated officer. The Project Manager shall be the Unit Leader Distribution Western, the Project Engineer shall be the Construction, Operations & Maintenance Engineer Western, and the Project Supervisor shall be the Construction Coordinator Western.
5. Insurance;
 - a) Contractor's risk – \$500,000.
 - b) Public Liability – \$500,000.
 - c) Worker's Compensation – \$250,000.The contractor shall indemnify FEA against any claims for liability, injuries, losses, damages etc that may arise during the execution of the works.
6. Liquidated and ascertained damages (refer clause 20): \$200/day.
7. Defects Liability period (refer clause 21): 6 months
8. Retention Fund (refer clause 24)
 - a) Limit of retention fund: 10% of contract sum.
 - b) Nature of retention fund: cash.
 - c) Release of retention fund: Subject to no pending defect, and as per FEA Finance Policy.

SECOND SCHEDULE

Specification for Distribution Powerline Construction at Savusavu Settlement – Ba.

1. General

This specification covers the installation of Distribution Power Lines at **Savusavu Settlement, Ba** as per attached Drawing No: A3/08/N82/325 Sheet 1 under conditions of Contract attached herein.

2. Scope of Work

Work involved in this contract is broadly classified into five phases:

- 2.1. Transportation of material.
- 2.2. Vegetation clearing.
- 2.3. Pole dressing, erection, stays, drop out fuses etc.
- 2.4. Stringing of conductors.
- 2.5. Transformer & earthing installation.

3. Phase One – Transportation of Material

The transportation of all material to the jobsite from FEA Depot, except for concrete poles which shall be picked up from either the FEA Depot or Humes Depot after instruction from FEA.

4. Phase Two – Vegetation Clearing

The second phase will involve the clearing of vegetation within 30m from the powerlines.

5. Phase Three – Pole dressing, erection, stays, drop out fuses etc.

This phase of the contract involves the dressing and erection of poles, the installation of stays, Drop out fuses etc.

6. Phase Four – Stringing of conductors

This phase involves the stringing of conductors to FEA standards, their binding, sagging etc.

CONTRACTOR REQUIREMENTS.

- 1) **Tender Bid** – Contractor shall submit a firm bid clearly listing unit costs for all items required. Vegetation clearing and Transportation costs shall be submitted as a lump sum.
- 2) **Site Visit** – Contractor shall participate in a site visit which is compulsory. Bids from tenderers who do not participate in the site visit shall be disqualified.
- 3) **Standards** – All construction work shall be in compliance with FEA Standard Overhead Line Design & Construction Manual.
- 4) **Safety Plan** – The tender bid shall include a Safety Plan that will be evaluated by the FEA's HSE Unit. Tender bids with incomplete, unacceptable, or without a Safety Plan will not be considered for award.
- 5) **Safety Record** – Tender bid shall include a brief report on Safety performance over the

last two years. The report shall include all incidents and accidents.

- 6) **Sub-contracting** – Subcontracting shall not be permitted, except where this is specifically presented in the tender bid, and only upon approval by FEA. Subcontractors shall be required to fulfil all requirements as if they were the contractor.
- 7) **Scope of works** - Work involved in this contract is broadly classified into six phases, and progress payments shall be processed accordingly.
 - i) Vegetation Clearing
 - ii) Transportation of material
 - iii) Pole dressed & erected. Stays installed
 - iv) Stringing of conductors, installation of ABS, Isolators and line dropouts.
 - v) Installation of transformers, earthing, etc
 - vi) Labelling of poles.
- 8) **Contact** - Contractor shall have a valid postal address, Office phone/fax/e-mail contact. The Principal shall be available by mobile phone at any time.
- 9) **Work Program** - Contractor shall submit a work program before starting of project. This shall be part of the contract. Work shall commence within seven (7) days after receiving an official FEA Local Purchase Order.
- 10) **Training** – Contractor shall ensure his employees have attended FEA Safety Manual Training and Pole Top Rescue Training at least once in the past 6 months, and records of this shall be submitted with the tender bid. In the event that the training has not been carried out, the Contractor shall ensure these training are carried **PRIOR** to induction for new project.
- 11) **Ground condition** – Contractors are to note that sub-soil comprises soapstone and could contain other services like Telecom Fiji Ltd, Water & Sewerage, etc.
- 12) **Lineman** – Contractor shall ensure that the project has one certified lineman and 3 registered Trainee Line Workers/ Linemen working on the project on a full time basis. Records of these personnel shall be submitted with the tender bid.
- 13) **Invoicing** – Contractor shall submit details of work completed to allow prompt approval of invoice.
- 14) **Safety Induction** - A Safety induction must be conducted before start of power line construction work.
- 15) **Instruction to Commence Work** - Contractor shall NOT commence work on site unless an “Instruction to Commence Work” has been received from the Project Manager.
- 16) **Signboards** - One signboard (6’X 4’) must be erected at the start of the works and one at the end of the works clearly stating :

<p>DANGER</p> <p>PROJECT: POWERLINE CONSTRUCTION – [Description of project]</p> <p>CONTRACTOR:</p> <p>POWER LINE CONSTRUCTION WORK.</p> <p>Please reduce speed. Pedestrians please use other footpath/side of road.</p> <p>THANKS</p>
--

- 17) **Accident Reporting** – All accidents and incidents shall be reported immediately to FEA using approved forms available in the FEA Safety Plan Template, or equivalent.
- 18) **Project Updates** - Contractor shall meet with FEA Project Manager, Project Engineer and Project Supervisor on a weekly basis to discuss project progress and bottlenecks. These meetings shall be minuted for records, and circulated to the appropriate stakeholders.
- 19) **Vegetation clearing** – Vegetation clearing shall be in accordance with FEA Vegetation Management Policy. Vegetation, which at a mature height will exceed 2m in height and will be within falling distance from the FEA lines are to be removed. Vegetation debris shall be disposed off neatly at a location agreed to by FEA. No debris shall be left by the roadside, or blocking drains.
- 20) **Tidiness** – The Contractor shall maintain the worksite in a neat and tidy condition.
- 21) **Consent for Vegetation clearing** – no vegetation shall be cleared unless specific instruction to do so has been received from the Project Supervisor. Notwithstanding this, the contractor shall inform the tree owner that he is required to clear the tree, and shall obtain the owner’s confirmation that he has given FEA his consent to remove the tree, prior to proceeding with cutting the tree.
- 22) **Fires** – No fires are to be lit at jobsites for the purpose of clearing vegetation or vegetation debris.
- 23) **Village Protocols** – the contractor shall comply with protocols involved in working on land owned by Indigenous Fijians to ensure smooth work progress.
- 24) **Transportation of material** – The Contractor shall transport all materials from Navutu FEA Depot work site, EXCEPT concrete poles, which may be picked up from Humes Depot.
- 25) **Security** - Contractor shall be responsible for the safekeeping of all materials at work site, and will be required to pay for damage and/or loss.
- 26) **Damage to property** – The Contractor shall ensure that there is no damage to roadways, footpaths, drains, water-courses, properties and other services. The Contractor shall make good to the satisfaction to the owner any damage caused by the contractor.
- 27) **Portable signboards** - Portable signboards must be placed at 50m intervals.
- 28) **Traffic and Pedestrian Control** – The Contractor shall ensure that there is minimum disruption to the flow of traffic and pedestrian. FEA procedures on Traffic Control and Pedestrian Control shall be diligently exercised.
- 29) **Worksite protection** - Bollards/cone must be placed at 10m intervals.
- 30) **Barricades** - Open trench/pole-hole is to be barricaded on a full time basis by the Contractor.
- 31) **Jobsite Safety Assessment** - Contractor to carry out Jobsite Safety Assessment daily, and as and when required, and submit these to FEA on a weekly basis.
- 32) **Contractor HSE Compliance** - Contractor shall comply with FEA/Contractor HSE Manual at all times.
- 33) **Credit of surplus material** – The contractor shall transport and credit all unused materials to Kinoya Stores.
- 34) **Defects Rectification** – The contractor shall rectify all defects within seven (7) days as per contract.
- 35) **Project completion** – The contractor shall complete work on time as per contract.
- 36) **Project progress** – If the Contractor fails to proceed with the works with reasonable diligence or suspends the works or refuses to comply with the reasonable direction from FEA by reason of which the works are materially affected and any such default continues

for a period of seven (7) days after the issue of written notice, FEA may itself call any other person to complete the works at the Contractor's risk and expense.

- 37) **Safe Work Procedure Training** - Contractor must have completed Distribution Safe Work Procedure training.
- 38) **FEA/Contractor HSE Manual** - Contractor shall comply with FEA/Contractor HSE Manual at all times.

FEA REQUIREMENTS.

1. FEA Project Supervisor shall obtain Road/footpath opening permits.
2. FEA Project Engineer shall obtain clearance from Municipal Council, Telecom Fiji Ltd, Water Supply Department, and Sewerage Department.
3. FEA's HSE Unit shall vet Safety Plan submitted by Contractor and approve after queries clarified by Contractor.
4. FEA Project Engineer shall ensure that any FEA underground mains on the jobsite is clearly located, marked and identified to the Contractor.
5. FEA Project Engineer shall submit to the Project Manager all necessary approval documentation from Municipal Council, Telecom Fiji Ltd, Water Supply Department and Sewerage Department. Upon receipt of these approvals, and the approved Safety Plan, the Project Manager shall issue an "Instruction to Commence Work" to the Contractor.
6. FEA Project Supervisor and Project Engineer shall carry out regular site inspections to ensure compliance with HSE requirements, and submit Safety Visit Reports of the visit.
7. FEA Project Supervisor and Project Engineer shall issue Non-Conformance Report if required, and follow up for verification of implementation of Action Items arising out of the Non-Conformance Report.

PAYMENT SCHEDULE.

Payment shall be made as per payment schedule:

Phase	Description	Percentage payment
1	Material Transportation to worksite	5%
2	Vegetation Clearing	10%
3	Pole dressing, erection, stays, ABS etc	50%
4	Conductor Stringing	25%
	Retention	10% to be released after 6 months pending zero defects.

Tender submission

Two (2) hard copies of the tender bids in sealed envelope shall be deposited in the tender box located at the Supply Chain Office at the FEA Head Office, 2 Marlow Street, Suva, Fiji.

Courier charges for delivery of Tender Document must be paid by the bidders.

This tender closes at 4:00pm on Tuesday 20th January, 2016. Any request for extension of the closing date by the bidders must be made 24hrs prior to the current closing date. It is the prerogative of the FEA to either accept or decline the request.

Site Inspection will be held at the FEA Navutu Depot at 10:00a.m on Tuesday 12th January, 2016.

Each tender shall be sealed in an envelope with:

The envelope bearing only the following marking:

Overhead Power line Construction Project

MR 01/2016 - Supply to Savusavu Settlement, Ba-Scheme:BA06-10

The Secretary, Tender Committee
Fiji Electricity Authority
Supply Chain Office

Private Mail Bag, Suva

It must also indicate the name and address of the tenderer on the reverse of the envelope.

All late tenders, unmarked envelopes and envelopes without bidder's name and address on the reverse will be returned to the Tenderers unopened.

For further information or clarification please contact our Supply Chain Office on phone **(+679) 3224360 or (+679) 9991587.**

TENDER SUBMISSION CHECK LIST

The Bidders must ensure that the details and documentation mention below must submitted as part of their tender Bid

Tender Number _____

Tender Name _____

1. Full Company
Name: _____
(Attach copy of Registration Certificate)

2. Director/Owner(s): _____
3. Postal
Address: _____

4. Phone
Contact: _____
5. Fax
Number: _____

6. Email
address: _____
7. Office
Location: _____
8. TIN
Number: _____
(Attach copy of the VAT/TIN Registration Certificate – Local Bidders Only)

9. Company Registration
Number: _____
(Attach copy of the Business License)

10. FNPF Employer Registration
Number: _____
(For Local Bidders only)

11. Contact Person: _____

I declare that all the above information is correct.

Name: _____ Position: _____ Sign: _____

Date: _____