

# NOTICE TO TENDERERS



**MWH**<sup>®</sup>

**BUILDING A BETTER WORLD**

---

**Number** Four

**Date:** 22 August 2016

**Reference:** 80507610

**Client** Fiji Electricity Authority

MWH New Zealand Ltd

**Project** Wailoa Power Station Generator Rehabilitation  
Tender No. MR58/2016

- 
1. Please find attached responses to the following questions raised by bidders for the above project:-

---

Q1. Is it possible to send more detailed drawings and material specification for the stub shaft that needs to be manufactured and replaced thanks?

A1. Design of the stub shaft modifications is the Contractors responsibility. The stub shaft material shall be stainless steel – grade 316 or similar. The Contractor may use the old exciter shaft for material if it suits their proposed arrangement.