

**FIJI ELECTRICITY AUTHORITY**



**TENDER SPECIFICATIONS**

**TENDER**

**TENDER NO: MR 58/2017**

**Supply of 4" Wafer type Butterfly Valves**

## **Supply of 4" Wafer type Butterfly Valves**

### **Tender Specifications**

Fea invites potential bidders to submit bids for the supply of wafer type 4 inch butterfly valves.

The valves will be used on pipe modules that carry high temperature water from the engine block to and from the radiator for cooling purposes.

**Below are the valve specifications:**

- 1. Body Type – Wafer (DN100)**
- 2. Nominal Diameter – 100mm (4inch)**
- 3. Working Pressure – 16 bar (PN16)**
- 4. Body – Cast Iron body**
- 5. Shaft – Stainless steel shaft**
- 6. Disk – Ductile iron or Stainless steel**
- 7. Liner – EPDM**
- 8. Actuation – lever type actuation**
- 9. Operating temperature range - -30'C – 120'C**

*FEA needs 32 butterfly valves suited to the above specifications to complete radiator installation works at Kinoya power station*

### **Note:**

***Bidders need to include delivery times in their bid, since the valves required are for works which are urgent in nature.***

FIJI ELECTRICITY AUTHORITY



**Supply of 4" Wafer type Butterfly Valves**

<b>Item</b>	<b>ITEM DESCRIPTION</b>	<b>UNIT PRICE</b>	<b>TOTAL PRICE</b>
1	Supply of 32 x DN100 wafer type butterfly valve		
2	Warranty		
	<b>TOTAL (VEP)</b>		
	<b>VAT 9%</b>		
	<b>TOTAL (VIP)</b>		

**Notes:**

1. FEA financial terms are applicable for these works.
2. Delivery time must be stated on the bids

## **Submission of Tender**

**Two (2) hard copies** of the tender bids in sealed envelope shall be deposited in the tender box located at the Supply Chain Office at the FEA Head Office, 2 Marlow Street, Suva, Fiji.

**Courier charges for delivery of Tender Document must be paid by the bidders.**

**This tender closes at 04.00pm on Wednesday, 22<sup>nd</sup> March, 2017.**

Each tender shall be sealed in an envelope with:

The envelope bearing only the following marking:

**Tender- MR 58/2017 – Supply of 4” Wafer type Butterfly Valves**

The Secretary, Tender Committee  
Fiji Electricity Authority  
Supply Chain Office  
Private Mail Bag, Suva

**It must also indicate the name and address of the tenderer on the reverse of the envelope.**

**All late tenders, unmarked Envelopes and envelopes without bidder's name and address on the reverse of the envelope. (Bids via e-mail or fax will not be considered).**

For further information or clarification please contact our Supply Chain Office on phone **(+679) 3224360** or **(+679) 9991587**.