

8th November 2021

Energy Fiji Limited

Suva

RE: ENERGY FIJI LIMITED

MR 209/2021 Supply of 1MW Containerized Generator for Rakiraki Power Station

NOTICE TO TENDERERS (NTT) NO: 1

This is a notification on an amendment and to clarify for the scope of supply:

- Item 2 – Supply of Controller Unit with the following abilities:
 - The new Generator Controller should be able to do synchronising to the Grid and also on Island Mode to other Generators.

- Item 3 – Supply of 2500VA Motorised Air Circuit Breaker with the highlighted abilities;
 - EFL Generators do sometimes take about 10% overload during Emergency thus our requirement of 2500A ACB for the generator which will also consider the effect of short circuit events.

Tenderers are to acknowledge this Notice to Tenderers No 1 with their tender submission.

Kind Regards



.....
Epeli Malo
Manager Thermal Generation
Generation
Energy Fiji Limited
9991908