



Addendum No: 1

Tender Number: MR41/2022

Tender Description: Roof Upgrade Works for Battery and Relay Room at EFL's National Control Centre, Vuda, Lautoka

Issue Date: 25-02-2022

This addendum is to clarify and or modify the following:

1. Additions and changes to the specifications and clauses for this services and contains the following:

Clause/Section	Addendum
Additional Scope of Work	<ol style="list-style-type: none">1. Supply and installation of heavy duty thermofoil sisalation 730M/Duty to Battery room roof.2. Supply and installation of heavy duty thermofoil sisalation 730M/Duty to Relay room roof.3. Water blast and apply 3 coats of paint to whole of Battery Room roof- paint colour match the existing.4. Water blast and apply 3 coats of paint to whole of Relay Room roof- paint colour match the existing.5. Supply and installation of infill strip to all the flashing joints for battery room.6. Supply and installation of infill strip to all the flashing joints for Relay room.




Bidders are encouraged to use pricing template below for bidding process:

Item	Trade	Price – VEP- FJD
1.0	Site Works	
2.0	Battery Room	
3.0	Relay Room	
4.0	Additional Scope	

Trade Totals \$.....VEP

9% VAT \$.....

Total Price \$..... VIP-FJD

Name of Approver	Shifaan Ali
Signature	
Date	25/02/22