



ENERGY FIJI LIMITED

**TECHNICAL SPECIFICATION FOR PREFERRED SUPPLIER OF
COMMERCIAL PILLAR BOX**

MR 117/2024

Revision History & Document Control

Rev No.	Notes	Prepared By	Reviewed & Approved By	Date of Issue
1	Prepared by	Rajiv Singh		18/09/19
2	Reviewed by		Kishan Kumar	26/09/19
3	Reviewed by		Hira N Shandil	26/09/19
4	Reviewed by		Mohammed Zainal Alim	19/03/24

Next Scheduled Revision

This technical specification is due for review in March 2027.

TABLE OF CONTENT

Revision History & Document Control.....	2
Next Scheduled Revision	2
1. INTRODUCTION AND SCOPE OF WORK.....	5
1 INSTRUCTIONS TO BIDDERS	6
1.1 Eligible Bidders	6
1.2 Eligible Materials, Equipment and Services	6
1.3 One Bid per Bidder	6
1.4 Cost of Bidding.....	6
1.5 Site Visits	6
1.6 Contents of Bidding Documents.....	7
1.7 Clarification of Bidding Documents.....	7
1.8 Amendment of Bidding Document	7
1.9 Language of Bid.....	7
1.10 Bid Prices.....	7
1.11 Bid Currencies	8
1.12 Bid Validity	8
1.13 Format and Signing of Bids	8
1.14 Sealing and Marking of Bids	8
1.15 Deadline for Submission of Bids.....	8
1.16 Late Bids	8
1.17 Modification and Withdrawal of Bids.....	8
1.18 Rejection of One or All Bids.....	9
1.19 Process to be Confidential.....	9
1.20 Clarification of Bids	9
1.21 Compliance with Specifications	9
2. REFERENCES.....	10
2.1. Applicable Standard	10
3. SERVICE CONDITIONS.....	11
3.1. Environmental Conditions.....	11
3.2. System Conditions	11
4. DESIGN AND CONSTRUCTION.....	12
4.1. General	12
4.2. Material	12
4.3. Busbars	12
4.4. Pre-fitted Accessories	12
4.4.1 Incoming.....	12
4.4.2 Outgoing.....	12
4.5. Spare Position	13

4.6.	Coating.....	13
4.7.	Night Reflective Sticker.....	13
5.	PERFORMANCE AND TESTING.....	14
5.1.	Type Testing	14
5.2.	Routine Tests	14
5.3.	Acceptance Tests	14
5.4.	Witnessing of Tests	14
5.5.	Compliance.....	14
6.	RELIABILITY	15
6.1.	Service Life.....	15
6.2.	Evidence in Support of Reliability.....	15
7.	ENVIRONMENTAL CONSIDERATIONS	15
8.	PACKAGING AND MARKING	15
8.1	Packaging.....	15
8.2	Marking.....	15
9.	QUALITY REQUIREMENTS	16
10.	STOCK AVAILABILITY	16
11.	PRODUCT WARRANTY PERIOD.....	16
12.	INFORMATION TO BE SUPPLIED BY THE BIDDER.....	16
12.1.	Documentation to be supplied with the tender.....	16
12.2.	Samples	17
12.3.	Training	17
13.	APPENDIX.....	18
13.1.	Price Schedule.....	18
13.2.	Technical Details – Commercial Pillar Box.....	19
13.3.	Submission Requirements	22

1. INTRODUCTION AND SCOPE OF WORK

Energy Fiji Limited [EFL] is responsible for generation, transmission and distribution of electricity in Viti Levu, Vanua Levu, Ovalau and Taveuni in Fiji. By January 2023, the EFL had 215,515 customers. This included residential, commercial and institutional customers.

EFL is requesting proposal for the Preferred Supplier to supply item listed below for EFL's operations to carryout repair, construction and maintenance of Power line Network in Fiji.

The preferred Supplier arrangement will be for a period of 3 (three) years from the date of signing of the contract.

This document outlines the technical requirements for commercial pillar box for use in EFL's low voltage (415V AC) distribution network.

The items covered by this specification are listed below:

No.	Stock Code	Item Description
1	I05035A	Commercial Pillar Box

Table 1.1: Items Covered Under this Specification

This Specification covers the general requirements of design, manufacture, testing, supply and delivery of commercial pillar box to be used in EFL's medium voltage distribution network.

1 INSTRUCTIONS TO BIDDERS

1.1 Eligible Bidders

This invitation is open to all Bidders who have sound Financial Background, and have previous experience in design, manufacture, testing and supply of such pole-mounted and platform-mounted transformers.

Bidders shall provide such evidence of their continued eligibility satisfactory to EFL as EFL shall reasonably request. Bidders who are not manufacturers of such transformers shall provide evidence of agency.

Bidders shall not be under a declaration of ineligibility for corrupt or fraudulent practice.

1.2 Eligible Materials, Equipment and Services

The materials, equipment, and services to be supplied under the Contract shall have their origin from reputable companies (as specified by EFL where relevant) and from various countries and all expenditures made under the Contract will be limited to such materials, equipment, and services. Upon request, bidders may be required to provide evidence of the origin of materials, equipment, and services.

For purposes of this Contract, "services" means the works and all related services including design services.

For purposes of this Contract, "origin" means the place where the materials and equipment are mined, grown, produced or manufactured, and from which the services are provided. Materials and equipment are produced when, through manufacturing, processing or substantial or major assembling of components, a commercial recognized product results that is substantially different in basic characteristics or in purpose or utility from its components.

The materials, equipment and services to be supplied under the Contract shall not infringe or violate any industrial property or intellectual property rights or claim of any third party.

1.3 One Bid per Bidder

Each bidder shall submit only one bid. A bidder who submits or participates in more than one bid will cause all those bids to be rejected.

1.4 Cost of Bidding

The bidder shall bear all costs associated with the preparation and submission of its bid and EFL will in no case be responsible or liable for those costs.

1.5 Site Visits

Bidders can visit existing EFL networks by making arrangements to visit existing EFL installations. Bidders are required to familiarize themselves with the existing EFL installations so the solutions they offer does not require modification to existing poles and support infrastructure.

1.6 Contents of Bidding Documents

The bidder is expected to examine carefully the contents of this Bidding document. Failure to comply with the requirements of bid submission will be at the bidder's own risk. Bids which are not substantially responsive to the requirements of the bidding documents will be rejected.

1.7 Clarification of Bidding Documents

A prospective bidder requiring any clarification of the bidding documents may notify EFL in writing by email, addressed to:

Jitendra Reddy
Manager Procurement, Inventory & Supply Chain
2 Marlow Street,
Suva, Fiji
Phone: +679 331 3333 Ext 2320 or
Mobile: +679 999 2400
Email: JReddy@efl.com.fj

EFL will respond to any request for clarification which it receives earlier than 10 days prior to the deadline for submission of bids.

1.8 Amendment of Bidding Document

At any time prior to the deadline for submission of bids, EFL may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, modify the bidding documents by issuing addenda.

1.9 Language of Bid

The bid, and all correspondence and documents related to the bid, exchanged between the bidder and the EFL shall be written in the English language.

1.10 Bid Prices

Unless specified otherwise, Bidders shall quote for the entire facilities on a "single responsibility" basis such that the total bid price covers all the Supplier's obligations mentioned in or to be reasonably inferred from the bidding documents in respect of the design, manufacture, including procurement and subcontracting (if any), testing and delivery.

Bidders shall give a breakdown of the prices in the manner and detail called for in this bidding document, or any issued addenda.

Bids shall be given on CIF basis. The point of delivery shall be EFL's Navutu Depot in Lautoka. The term CIF shall be governed by the rules prescribed in the current edition of Incoterms, published by the International Chamber of Commerce, Paris.

EFL has a marine insurance cover for items it is required for purchase for its project and operational works. Bidders are required to comment if the marine insurance component is covered in their bids.

1.11 Bid Currencies

Prices shall be quoted in a single currency only.

1.12 Bid Validity

Bids shall remain valid for a period of **120 days** from the date of Deadline for Submission of Bids specified in Sub-Clause 21.1.

1.13 Format and Signing of Bids

The bidder shall provide one electronic copy of the Technical and Financial proposals on EFL's electronic tender hosting website; <https://www.tenderlink.com/efl>

The bid shall contain no alterations, omissions or additions, except those to comply with instructions issued by EFL, or as necessary to correct errors made by the bidder, in which case such corrections shall be initialed by the person or persons signing the bid.

1.14 Sealing and Marking of Bids

Due to the Covid19 restrictions on movements, bidders are encouraged to bid via Tender link Portal.

1.15 Deadline for Submission of Bids

Bids must be received by EFL at the address specified above no later than **1600 hours (Fiji Time) 1st May 2024**.

EFL may, at its discretion, extend the deadline for submission of bids by issuing an addendum, in which case all rights and obligations of EFL and the bidders previously subject to the original deadline will thereafter be subject to the deadlines extended.

1.16 Late Bids

Any bid received by EFL after the deadline for submission of bids prescribed above will be rejected.

1.17 Modification and Withdrawal of Bids

The bidder may modify or withdraw its bid after bid submission, provided that written notice of the modification or withdrawal is received by EFL prior to the deadline for submission of bids.

No bid may be modified by the bidder after the deadline for submission of bids.

1.18 Rejection of One or All Bids

EFL reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders of the grounds for the rejection.

1.19 Process to be Confidential

- 2.19.1. Information relating to the examination, clarification, evaluation and comparison of bids and recommendations for the award of a contract shall not be disclosed to bidders or any other persons not officially concerned with such process.
- 2.19.2. Any effort by a bidder to influence EFL's processing of bids or award decisions may result in the rejection of the bidder's bid.
- 2.19.3. Lowest bid will not necessarily be accepted as successful bid.

1.20 Clarification of Bids

To assist in the examination, evaluation and comparison of bids, EFL may, at its discretion, ask any bidder for clarification of its bid. The request for clarification and the response shall be in writing, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction of arithmetic errors discovered by EFL in the evaluation of the bids.

1.21 Compliance with Specifications

The tender shall be based on the equipment and work specified and shall be in accordance with the Technical Specification. It should be noted that unless departures from specifications are detailed in Schedules of the Technical Specification, the tender would be taken as conforming to the Specification in its entirety. The Bidder shall tender for the whole of the Works included in the Specification.

2. REFERENCES

2.1. Applicable Standard

The item shall be designed, manufactured and tested in accordance with the latest edition of the Standards specified below and all amendments issued prior to the date of closing of tenders except where varied by this specification.

AS/NZS IEC 61439.5	Low-voltage switchgear and controlgear assemblies. Part 5: Assemblies for power distribution in public networks
IEC 60529	Degrees of protection provided by enclosures (IP code)
IEC 60269.1	Low voltage fuses – Part 1: General requirements
AS 2700	Color standards for general purpose
AS/NZS ISO:9001	Quality Management Systems – model for quality assurance in design, development, production, installation and servicing
AS ISO/IEC 17025	General requirements for the competence of testing and calibration laboratories

Should inconsistencies be identified between standards and/or this specification, the tenderer shall immediately refer such inconsistencies to the EFL for resolution.

3. SERVICE CONDITIONS

3.1. Environmental Conditions

The commercial pillar box shall be suitable for installation outdoors and shall be designed to withstand the following service conditions.

Description	Conditions
Atmosphere Pollution Level	: Saliferous, Corrosive and Dusty
Ambient Temperature	: Peak: 40°C 24 Hour Average: 30°C Annual Average: 22°C Minimum: 10°C
Relative Humidity (Average)	: 90%
Rainfall	: Annual Average: 2663mm
Isokeraunic (Thunder day) level	: 60 thunder days per year
Seismic	: To a maximum of 7 on the open-ended Richter Scale

Note: Fiji is situated in a region where cyclones are experienced frequently. All plant and equipment shall be designed and constructed to withstand these extreme conditions. All plant and equipment shall be rust proof, vermin proof and weather proof and designed to be suitable for a damp, tropical climate, which may be experienced simultaneously.

3.2. System Conditions

Nominal Voltage	240/415 V
System Highest Voltage	660 V
System Frequency	50Hz
Number of Phases	1 or 3
System Earthing	Effectively Earthed
Impulse Withstand Voltage (peak)	-
Power Frequency Withstand Voltage	15 kV (rms)

4. DESIGN AND CONSTRUCTION

4.1. General

This Specification comprises general, technical and performance requirements for commercial pillar box.

4.2. Material

The commercial pillar box shall be manufactured in accordance with AS/NZS IEC 61439.5. The material for the commercial pillar box shall be machine made out of fiberglass reinforced polyester with 25% class content under comparison and temperature.

The commercial pillar box shall have the following dimensions:

- a) 1622mm height
- b) 425mm width
- c) 240mm depth

The expected above ground level height of the commercial box shall be 950mm.

Note: EFL requires bidders to strictly maintain the above dimensions for system compatibility.

4.3. Busbars

The commercial pillar box shall be fitted with the following:

- a) Three (3) by 50 x 60 mm, 700A, tin plated phase busbars. The busbars shall be supplied with M8 and M12 inserts with stainless steel screws for mounting vertical fuse disconnectors.
- b) One (1) by 50 x 60 mm, 700A, tin plated earth/neutral busbar. The busbar shall be supplied with M12 inserts with stainless steel screws for earth & neutral connections.

4.4. Pre-fitted Accessories

4.4.1 Incoming

The commercial pillar box shall be pre-fitted with the following:

- a) One (1) vertical fuse disconnector (type: PU-SL3-3x3/3A)
- b) The vertical fuse disconnector shall have a 3 pole operation (one action switching)
- c) Rating for the vertical disconnector shall be 400A
- d) The vertical fuse disconnectors shall have pre-fitted solid links for 3 phases
- e) The vertical fuse disconnectors shall be supplied with terminal extensions for connection of two (2) cables per phase

Note: Type PU-SL3-3x3-3A is the current product used by EFL.

4.4.2 Outgoing

The commercial pillar box shall be pre-fitted with the following:

- a) Two (2) vertical fuse disconnector (type: SL00-3x185/F)
- b) The vertical fuse disconnector shall have a single pole operation
- c) Rating for the vertical disconnector shall be 160A

Note: Type SL00-3x185/F is the current product used by EFL.

4.5. Spare Position

The commercial pillar box shall have the following spare locations for fitting vertical fuse disconnectors:

- a) One (1) by SL1 – 250A
- b) Or two (2) by SL00 – 160A

Customers may also need 400A outgoing, 630A outgoing as per the fuse sizes currently in EFL's stock.

Note: Types SL1-250A and SL00-160A is the current product used by EFL.

Protection

The commercial pillar box shall have the following protection types for operator safety:

- a) The spare busbar shall be covered/ insulated.
- b) All vertical fuse disconnectors shall be fitted with terminal extension covers.
- c) The pillar box shall be fitted with a **Lockwood** lock keyed to EFL standard. The details for this will be provided to the bidder who is awarded the tender. Note that there are 2 types of standard locks used by EFL.

4.6. Coating

The commercial pillar box shall be coated with two components acrylic laquer in grey color according to AS 2700 and EFL requirement.

4.7. Night Reflective Sticker

The commercial pillar box shall be supplied with the following sticker (or similar) as a warning and visible sign for the pedestrians and motorist at night. The sign shall be permanent for the life of the pillar box.



5. PERFORMANCE AND TESTING

5.1. Type Testing

Type tests, sampling tests and routine tests shall be done in accordance with the requirements of **AS/NZS IEC 61439.5** and this specification. It shall be the responsibility of the supplier to perform or to have performed all the tests specified.

Copies of Type Test Certificates & Type Test Reports issued by a third party testing laboratory that is accredited to ISO/IEC 17025 shall be submitted with the tender for the purpose of technical evaluation. A copy of the accreditation certificate to ISO/IEC 17025 for the testing laboratory shall also be submitted (all in English language).

Copies of type test reports to be submitted with the tender (by bidder) for evaluation shall be as per the table below:

Test Required	Testing Standard
Dry heat test	AS/NZS IEC 61439.5 part 10.2.3.101
Verified mechanical impact	AS/NZS IEC 61439.5 part 10.2.101
Category of flammability test	AS/NZS IEC 61439.5 part 10.2.3.102
IP rating of pillar box enclosure to meet IP 44	IEC 60529

The bidders are to take note that the above table does not limit the tests that may be conducted on the commercial pillar boxes.

5.2. Routine Tests

A sample shall be taken in random from each lot ready for delivery and shall be subjected to the tests in accordance with **AS/NZS IEC 61439.5**.

5.3. Acceptance Tests

The EFL may carry out acceptance test on equipment to prove it conforms to the requirements of this Specification. Any equipment showing evidence of failure to comply with the requirements of this specification will be liable to rejection.

5.4. Witnessing of Tests

The EFL reserves the right to witness all testing. The Supplier shall give EFL reasonable notice of when testing will be carried out and two (2) EFL engineers to be invited to witness the testing. The return-air travel, accommodation, meals and other expense related to test witnessing shall be borne by the Bidder as a value adding service.

Note the Factory Acceptance Testing (FAT) is a mandatory requirement by EFL.

5.5. Compliance

The Supplier shall state in writing that their offer complies with the relevant Standards and this specification. If the Supplier is offering equipment manufactured to an equivalent standard, full details of that standard must be given including a copy written in English.

6. RELIABILITY

6.1. Service Life

Bidders are required to comment on the reliability of the equipment and the performance of the materials offered for a service life of 35 years under the specified system and environmental conditions in clause 3.

6.2. Evidence in Support of Reliability

Where the specified guaranteed service life is less than 35 years Suppliers are required to provide comment and submit evidence in support of the reliability and performance claimed including detailed information on Failure Mode and Effect Analysis.

7. ENVIRONMENTAL CONSIDERATIONS

Suppliers are required to comment on the environmental soundness of the design and the materials used in the manufacture of the items offered. In particular, comments should address such issues as recyclability and disposal at end of service life and also disposal of packaging material.

8. PACKAGING AND MARKING

8.1 Packaging

The packaging of items by the bidder must ensure that they are capable of being delivered undamaged giving due consideration to the quantity, distance of transportation and the preferred method of handling at each location.

Each packaged lot shall be marked with the following information:

- Manufactures Name
- Purchase Order Number
- Contact No.
- EFL Stock Code
- Item Description
- Applicable standards
- Pack Size
- Pack Weight

8.2 Marking

The following information shall be marked indelibly and legibly on a nameplate permanently attached to the commercial pillar box in English language:

- Rated voltage
- Rated frequency
- The manufacturer's name or trade mark
- The year of manufacture
- The letter "**PROPERTY OF EFL**"

9. QUALITY REQUIREMENTS

Tenderers are required to submit evidence that the design and manufacture of the commercial pillar boxes are in accordance with AS/NZS ISO 9001 and shall include the Capability Statement associated with the Quality System Certification.

If the Tenderer is a non-manufacturing supplier, the documentary evidence shall include the quality system certifications of both the supplier and the manufacturer.

10. STOCK AVAILABILITY

The bidder is required to indicate the size of consignment stock it will hold and the ability to meet the required demand of the estimated quantity at any given time during the contract period. The movement of the commercial pillar boxes will depend on the EFL's project works and for operation and maintenance purposes. An estimate movement of the item is outlined in the table below but the commercial pillar boxes will not be purchased as a lump sum quantity at once. Hence, the successful bidder will be required to carry a consignment / safety stock at times to meet EFL's demand within the three year contract period.

No.	Stock Code	Item Description	Approximate 3 Year Stock Movement
1	I05035A	Commercial Pillar Box	96

11. PRODUCT WARRANTY PERIOD

The bidders are required to provide the warranty period as part of the proposal. A minimum warranty period of twenty-four (24) months in service warranty and one (1) year shelf warranty is required by EFL.

12. INFORMATION TO BE SUPPLIED BY THE BIDDER

12.1. Documentation to be supplied with the tender

To enable EFL to fully evaluate the commercial pillar boxes offered, (in addition to the completed Specification Requirement and Guaranteed Performance schedule) bidders shall submit the following information with their tender: **(Note these are mandatory requirements)**

- List showing similar equipment supplied to or on order for other utilities in Australia or New Zealand or the Oceania region for the past 5 years
- Typical arrangement drawings and full details of the dimensions including drawings for the accessories offered. The bidder is required to provide EFL with complete dimensional drawings of the commercial pillar box. This needs to be in AutoCAD or PDF format allowing EFL to reuse the drawings for documentation purpose.
- Type test certificates as per Clause 5.1 and 5.2
- End of service life disposal methods
- Evidence of Quality Management Systems used in the manufacturing process
- Evidence of Health, Safety and Environmental plans
- Evidence of financial ability to provide the level of service and support
- Origin of materials used in manufacture of the commercial pillar boxes
- Names and resumes of key team members who will be assigned to work with EFL upon successful award of the three-year supply contract (if bidder is successful)

Bidders may be asked to provide additional information during tender assessment period or following award of contract.

12.2. Samples

When requested, production samples of each item shall be submitted with the offer.

Each sample shall be delivered freight free (Delivery Duty Paid (DDP)), suitably packaged and labelled with the following information:

- Name of supplier and contact number
- Tender number
- Any supporting data on features or characteristics

12.3. Training

Training material in the form of drawings, instructions and/or audio visuals (in CD format) are required to be provided for the items accepted under the tender. The Tenderers shall allow the cost of production and delivery of training material in the tendered prices.

The training materials should include but not be limited to the following topics:

- Handling
- Storage
- Application
- Installation
- Maintenance
- Environmental performance
- Electrical performance
- Mechanical performance
- Disposal

Offers of vendors who fail to furnish above particulars shall be rejected.

13. APPENDIX

13.1. Price Schedule

Bidders are required to complete the following price schedule and submit with the offer. EFL requires the bidding prices to be in CIF incoterms.

No.	Stock Code	Item Description	Unit Price (CIF)	Currency of bid
1	I05035A	Commercial Pillar Box		
2		Factory Acceptance Testing (FAT) for 2 EFL Engineers.		

Bidders are to clearly indicate the currency of bid.

13.2. Technical Details – Commercial Pillar Box

This schedule shall be completed and submitted with the offer. A separate schedule shall be provided for each item offered: **(Note these are mandatory requirements)**

Particulars	Requirements	Bidders Response
Name of Manufacturer		
Origin of materials used for manufacturing of pillar box		
Country of manufacture		
Manufactures type test certificate number		
Name of testing authority		
General		
Ability to operate in environmental and system conditions as per Clause 3.0 of this specification		
Complete dimensional drawing provided for commercial pillar box complete with accessories	Mandatory requirement	
Manufactured to AS/NZS IEC 61439.5	Yes/ No	
Pillar Box Material		
Pillar box material	Fiberglass reinforced polyester with 25% class content under comparison and temperature	
Pillar box dimensions:		
a) Height	1622mm	
b) Width	425mm	
c) Depth	240mm	
Expected height above ground level	950mm	
Busbars		
Phase		
Busbar type	Tin plated copper	
Number of busbars	3	
Dimensions	50 x 60 mm	
Rating	700A	
Supplied with M8 and M12 inserts with stainless steel screws for mounting vertical fuse disconnectors	Mandatory requirement	
Neutral		

Busbar type	Tin plated copper	
Number of busbars	1	
Dimensions	50 x 60 mm	
Rating	700A	
Supplied with M12 inserts with stainless steel screws for earth & neutral connections	Mandatory requirement	
Pre-fitted Accessories		
Incoming		
Vertical Fuse Disconnecter	1 x PU-SL3-3x3/3A	
Operation	3 pole – one action switching	
Rating	400A	
Solid links	Pre-fitted for 3 phase	
Supplied with terminal extensions for connection of 2 cables per phase	Mandatory requirement	
Outgoing		
Vertical Fuse Disconnecter	2 x SL00-3x185/F	
Operation	Single pole operation	
Rating	160A	
Solid links	Pre-fitted for 3 phase	
Spare Position for Mounting VFD		
Spare position available for mounting one vertical fuse disconnecter	1 x SL1 – 250A	
Spare position available for mounting two vertical fuse disconnecter	2 x SL00 – 160A	
Protection		
All spare busbars shall be covered/ insulated	Mandatory requirement	
All vertical fuse disconnecters shall be fitted with terminal extension covers	Mandatory requirement	
The pillar box shall be fitted with a key lock keyed to EFL standard lock. The details for this will be provided to the bidder who is awarded the tender	Mandatory requirement	
Coating		
Shall be coated with two components acrylic laquer in grey color	Mandatory requirement	
Packaging Details		

Packaging type		To be stated by bidder	
Weight of each unit		To be stated by bidder	

Name of Tenderer: _____

Signature of Tenderer: _____

Date: _____

13.3. Submission Requirements

All tenderers are required to complete and submit a copy of the submission requirements with their bid submissions. **(Note these are mandatory requirements)**

Requirements	Response from Bidders
Validity of bid (120 days required) (Yes/No)	
List of test reports/certificates provided. (As per Clause 5)	
Minimum warranty period offered for this product	
Completed price and technical schedules (Clause 13.1 and 13.2) (Yes/No)	
The bidding pricing to be in CIF incoterm.	
Currency of bid.	
Lead time of delivery after tender award.	
Bidders company profile outlining financial, technical and production capabilities.	
Disposal method after service life.	
Quality management system used in the production of commercial pillar box, attached certificate.	
Material safety datasheet to be provided for all items	
The bidder to include the following as part of the bid:	
Company profile	
Company registration details	
Company financial capability statement	
Reference list of customers the same product is supplied to and contact details for reference check	
If the bidder is the manufacturer, the ISO certification shall be provided	
If the bidder is only the supplier of the product, then both the manufacturer and supplier ISO certifications shall be provided	

Name of Tenderer: _____

Signature of Tenderer: _____

Date: _____

Complete the following schedule as part of the bid: (Note these are mandatory requirements)

Stock Codes	Items	Country of Manufacture	Manufacturer of product	Brand Offered	Manufactured to standards	ISO Certification of Manufacturer	Lead time of delivery
I05035A	Commercial Pillar Box						

Name of Tenderer: _____

Signature of Tenderer: _____

Date: _____

TENDER CHECKLIST

The Bidders must ensure that the details and documentation mention below must be submitted as part of their tender Bid

Tender Number _____

Tender Name _____

1. Full Company / Business Name: _____

(Attach copy of Registration Certificate)

2. Director/Owner(s): _____

3. Postal Address: _____

4. Phone Contact: _____

5. Fax Number: _____

6. Email address: _____

7. Office Location: _____

8. TIN Number: _____

(Attach copy of the VAT/TIN Registration Certificate - Local Bidders Only (Mandatory))

9. FNPF Employer Registration Number: _____ **(For Local Bidders only) (Mandatory)**

10. **Provide a copy of Valid FNPF Compliance Certificate (Mandatory- Local Bidders only)**

11. **Provide a copy of Valid FRCS (Tax) Compliance Certificate (Mandatory Local Bidders only)**

12. **Provide a copy of Valid FNU Compliance Certificate (Mandatory Local Bidders only)**

13. Contact Person: _____

I declare that all the above information is correct.

Name: _____

Position: _____

Sign: _____

Date: _____

Tender submission

Bidders are requested to upload electronic copies via Tender Link by registering their interest at: <https://www.tenderlink.com/efl>

EFL will not accept any hard copy submission to be dropped in the tender box at EFL Head Office in Suva.

This tender closes at 4.00pm (1600hrs) on Wednesday 1st May, 2024.

For further information or clarification please contact our Supply Chain Office on phone **(+679) 3224360** or **(+679) 9992400** or email us on tenders@efl.com.fj

The bidders must ensure that their bid is inclusive of all Taxes payable under Fiji Income Tax Act. Bidders are to clearly state the percentage of VAT that is applicable to the bid prices.

The lowest bid will not necessarily be accepted as the successful bid.

The Tender Bids particularly the “Price” must be typed and not hand written.

Any request for the extension of the closing date must be addressed to EFL in writing three (3) working days prior to the tender closing date.

Tender Submission via email or fax will not be accepted.